

**PERMIT APPROVAL SPECIFICATIONS**  
Sanders County Environmental Health Department  
1111 Main St. Thompson Falls, MT, 59873 \* 406.827.6961

Owner information:

**Roberta Ann Pierce (Lots 10&11)**

**8 21N 29W**

Name

**PO Box 1801**

S T R

**June 8, 2007**

Mailing address

**Thompson Falls, MT 59873**

Date Submitted

**June 20, 2007**

City

**07-201**

Date Approved

**June 20, 2008**

Permit Number

**209 Woodland**

Expiration Date

Physical Address

Permit Specifications: 3 number of bedrooms

**Pressure dosed drainfield required**

This permit is approved with the following specifications:

**1000 septic/500 pump**

\_\_\_\_\_ gallon size of septic tank



Drainfield Design specifications:

**Gravelless Chambers:**

125 lineal feet

375 square feet

3 laterals @ 42 feet

**Trenches are 3 feet wide and a maximum depth of 36 inches. Please follow all county wastewater regulations & the state regulations as outlined in Circular DEQ 4 2002 edition. Install the system exactly as per approved lot layout. Pre-notification is mandatory 72 hours before backfilling system.**

*Barbara Woodbury R.S.*  
\_\_\_\_\_  
Sanders County Sanitarian




60.92'



← EXISTING TREES

← EXISTING LARGE BouldERS



**APPROVED**  
DATE 7/27/07 INITIAL *fw*

137.88'

← EXISTING MATURE TREE

DRIVEWAY TO BE DETERMINED BY EXISTING TREE LOCATION.

EXISTING LILACS

RECEIVED  
JUL 19 2007  
BY \_\_\_\_\_

WOOD LAND STREET